

HOW TO CHECK PHASE SEQUENCE (cont'd)





Fig. 3

WARRANTY STATEMENT

This tester is warranted to the original purchaser against defects in material and workmanship for two years from the date of purchase. During this warranty period, IDEAL INDUSTRIES, INC. will, at its option, replace or repair the defective unit, subject to verification of the defect or malfunction. This warranty does not cover fuses, batteries or damage from abuse, neglect, accident, unauthorized repair, alteration, or unreasonable use of the instrument.

Any implied warranties arising out of the sale of an IDEAL product, including but not limited to implied warranties of merchantability and fitness for a particular purpose, are limited to the above. The manufacturer shall not be liable for loss of use of the instrument or other incidental or consequential damages, expenses, or economic loss, or for any claim or claims for such damage, expenses or economic loss.

State laws vary, so the above limitations or exclusions may not apply to you. This warranty gives you specific legal rights, and you may also have other rights which vary from state to state.



#61-520

OPERATING INSTRUCTIONS PHASE SEQUENCE AND OPEN PHASE INDICATOR

PLEASE READ CAREFULLY

Misuse and abuse of these instructions cannot be prevented by any printed word and may cause injury and or equipment damage. Please follow these instructions faithfully and adhere to all standard industry safety rules.



Shown Approx.
1/3 Actual Size

IDEAL INDUSTRIES, INC.
Sycamore, IL 60178, U.S.A.
800-304-3578 Customer Assistance
www.idealindustries.com
ND 1714-2

Test Equipment Depot
1-800-517-8431

99 Washington Street
Melrose, MA 02176
Fax 781-665-0780
TestEquipmentDepot.com

FRONT PANEL VIEW



Rotating Disc

Phase Sequence Indication Window

Phase Designation

"Open Phase" Check Lamps

Push Button Switch

Page 3

Fig. 1.

HOW TO CHECK PHASE SEQUENCE (cont'd)




Fig. 2

The Model 61-520 is a positive action electrical tester and will indicate both Phase Sequence and Phase Continuity instantly and accurately.

PACKAGING

Packed in handy unit box, complete with C-31 Pouch, Form ND-1714 Operating Instructions and Warranty Card, all ready to use.